Evaluation

200242-H (Replaces 960019-H)

Safety & Buildings Division 201 West Washington Avenue P.O. Box 2658 Madison, WI 53701-2658

Wisconsin Building Product Evaluation

Hot Water Boilers: GV Gold Series

Manufacturer: Weil-McLain

A United Dominion Company

500 Blaine Street

Michigan City, Indiana 46360

Approved Product(s): Trade Name: **Weil-McLain** GV-3, -4, -5, -6) For installation on combustible flooring.

SCOPE OF EVALUATION: General: This report evaluates the use of GV Gold Series natural or propane gas-fired hot water boilers, manufactured by Weil-McLain, A Dominion Company.

This review includes the cited **Comm** code requirements below in accordance with the current **Wisconsin Uniform Dwelling Code** (**UDC**), for 1- & 2-family dwellings): Equipment shall be located in accordance with s. Comm 23.04(3) & (4). ♣

This review includes the cited **Comm** code requirements below in accordance with the **Wisconsin Building and Heating**, **Ventilating and Air Conditioning Code (expires 6/30/02):** The models listed herein were evaluated in accordance with **s. Comm 51.01(29a)** and **s. Comm 64.21.** ♣

"This evaluation was based on receipt of a signed statement from the testing agency that the product passed the Wisconsin code required test(s) see test section. No other Department evaluation was conducted."

Applicant/Manufacture Date:	r: —
ANSI Z21.47 (ANSI Z2 requires the use of tools	21.64): Access to the combustion chambers.
	P.E.
Date:	

This review includes the cited **International Building Code** (**IBC**) requirements below in accordance with the current **Wisconsin Amended IBC Code** (effective 7/01/02):

The models listed herein were evaluated in accordance with s. IBC 302.1, the International Mechanical Code s. IMC Comm 64.1001, and the International Fuel Gas Code s. IFGC 630.1

<u>TESTS</u>: ♣Tested and certified in accordance with ANSI Z21.13 & Z21.13a by AGA as Direct Vent Sealed Combustion Chamber Appliances, and as specified in s. Comm 51.01 (29a) and s. Comm 64.21.

<u>LIMITATIONS OF APPROVAL</u>: The boilers shall be installed in accordance with **Ch. Comm 41**, this evaluation, their listing and the manufacturer's recommendations.

Architectural and mechanical plans and specifications shall be submitted in accordance with the pertinent code.

Wisconsin Uniform Dwelling Code: Combustion air shall be in accordance with s. Comm 23.06(1). Equipment shall be maintained in accordance with s. Comm 23.065. Piping shall be in accordance with s. Comm 23.10(1).

This approval will be valid through December 31, 2007, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department.

The Wisconsin Building Products Evaluation number must be provided when plans that include this product are submitted for review.

<u>DISCLAIMER</u>: The department is in no way endorsing or advertising this product. This approval addresses only the specified applications for the product and does not waive any code requirement not specified in this document.

Revision Date: Approval Date: Augus	st 26, 2002 By:
	Lee E. Finley, Jr.
	Product/Material &
	Building Plan Review
	Integrated Services Bureau

200242-H.doc